PERMIT CONDITIONS

Columbia Falls Aluminum Company Permit No. 2568

- 1. Opacity shall not exceed 40% as measured by EPA Method 9.
- 2. Particulate emissions shall demonstrate a minimum of 96% control as measured by EPA Source Testing Methods 1-5.
- 3. A stack test shall be required on both the inlet and outlet gas streams of the scrubber in order to demonstrate compliance with condition #2. Said tests shall be completed and submitted to the department within 180 days of startup. These tests shall be conducted in compliance with the Montana Source Testing Protocol.
- 4. All general conditions on the attached sheet shall apply.

General Conditions

A. Inspection

The recipient shall allow the department's representatives access to the source at all reasonable times for the purpose of making inspections, surveys, collecting samples, obtaining data, and otherwise conducting all necessary functions related to this permit.

B. Waiver

The permit and all the terms, conditions, and matters stated herein shall be deemed accepted if the recipient fails to appeal as indicated below.

C. Compliance with Statutes and Regulations

Specific listing of requirements, limitations, and conditions contained herein does not relieve the applicant from compliance with all applicable statutes and administrative regulations including amendments thereto, nor waive the right of the department to require compliance with all applicable statutes and administrative regulations, including amendments thereto.

D. Enforcement

Violations of limitations, conditions and requirements contained herein may constitute grounds for permit revocation, penalties or other enforcement as specified in Section 75-2-401, MCA.

E. Appeals

Any person or persons who are jointly or severally adversely affected by the department's decision may request, within fifteen (15) days after the department renders its decision, upon affidavit, setting forth the grounds therefore, a hearing before the board. A hearing shall be held inder the problem of the Montana Administrative Procedures Act. The department's decision on the application is not final unless fifteen (15) days have elapsed and there is no request for a hearing under this section. The filling of a request for a hearing postpones the effective date of the department's decision until the conclusion of the hearing and issuance of a final decision by the board.

F. Application Data

Information submitted on behalf of an air quality permit application is hereby incorporated as a condition of that permit including commencement and completion dates of construction.

G. Permit Inspection

As required by ARM 16.8.1115 Inspection of Permit, a copy of the air quality permit shall be made available for inspection by air quality personnel at the location of the permitted source.